

TEST REPORT

FF : 7.8.1.1

Issued To:	M/s. Sunita Gyan Niketan School Village & Post Office Chhawla, Delhi-110071 New Delhi, India.	Work Order No.	AMCO/603/07
		Report No.	26081107
Page 1 of 1		Date of Receipt:	11-08-2026
		Party Ref. No.	PV & Letter Dated 11-08-2026
		Letter Ref. No.	S.G.N.S/2026
		Order Confirmation Date:	11-08-2026
		Analysis Start Date:	11-08-2026
		Analysis End Date:	17-08-2026
Sample Quantity:	Approx 2 litre	Date of Issue:	17-08-2026
Lot No /Batch No	Not Specified	Sample Deposited by Party	
Date of Manufacturing	Not Specified		
Sample Description: One Sample described by party as Water for Drinking purpose, was received for the following tests only.			

TESTS RESULTS

WATER SAMPLE ANALYSIS REPORT

S.NO	TESTS	TEST METHODS	RESULTS	REQUIREMENTS As per (IS:10500-2012) Ammn 2	CONFORMITY
1	Odour	IS: 3025 (PART-5)-2018 RA: 2022	Agreeable	Agreeable	YES
2	Colour, Hazen Units	IS: 3025 (PART-4)-2021	<5	A. 5 max as acceptable limit B. 15 max as Permissible Limit	YES
3	pH Value @25° C	IS: 3025 (PART-11)-2022	7.10	6.5 to 8.5	YES
4	Total Dissolved Solids, mg/l	IS: 3025 (PART-16)-2023	33	A. 500 max as acceptable limit B. 2000 max as permissible limit	YES
5	Turbidity, NTU	IS: 3025 (PART-10)-2023	<1	A. 1 max as acceptable limit B. 5 max as permissible limit	YES
6	Chloride as Cl ⁻ , mg/l	IS: 3025(PART-32)-1988 RA: 2019	4.15	A. 250 max as acceptable limit B. 1000 max as permissible limit	YES
7	Calcium as Ca, mg/l	IS: 3025 (PART-21)-09RA: 2023	3.94	A. 75 max as acceptable limit B. 200 max as permissible limit	YES
8	Magnesium as Mg, mg/l	IS: 3025 (PART-46)-2023	2.36	A. 30 max as acceptable limit B. 100 max as permissible limit	YES
9	Total Hardness as CaCO ₃ , mg/l	IS: 3025 (PART-21)-2009 RA: 2023	19.7	A. 200 max as acceptable limit B. 600 max as permissible limit	YES
10	Flouride as F, mg/l	IS:3025 (PART 60)-2008 RA 2023	BDL(DL=0.1)	A. 1.0 max as acceptable limit B. 1.5 max as permissible limit	YES
11	Iron as Fe, mg/l	IS: 3025 (PART-53)-2003 RA: 2023	BDL(DL=0.1)	A. 1.0 max as acceptable limit	YES
BACTERIOLOGICAL TESTS					
12	Coliform	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES
13	E. Coli	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES

Note:1) BDL: Below Detection Limit. 2) Figure in bracket indicates Limit of Quantification, 3) ND= Not detected, DL= Detection Limit.
Remarks: The above sample confirms to IS: 10500-2012 wrt above tests only.

REVIEWED



NITIN KANDON
Authorised Signatory

Civil / Mechanical / Chemical / NDT

1. The results listed refer only to samples and applicable parameters. 2. Endorsement of product is neither inferred nor implied. 3. Total liability of our lab is limited to the invoiced amount. 4. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 5. Perishable samples will be destroyed in 2 to 7 days as applicable. 6. The Report shall not be reproduced except in full without written approval of Laboratory. 7. Report refers to the sample submitted to us and not drawn by Amco Spectro and Material Testing Lab LLP unless mentioned otherwise. 8. Retesting Charges will be applicable if results are reproducible. 9. Duplicate copy will be issued on chargeable basis. 10. In case of any dispute, the jurisdiction shall be New Delhi Courts



MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER: NAJAFGARH ZONE
ROOM NO.408, 4TH FLOOR, ZONAL BUILDING, DHANSA STAND,
NAJAFGARH, NEW DELHI 110043



No.DHO/NGZ/2025/-D-1364

Dated 13/10/25

SCHOOL HEALTH CERTIFICATE

1. Name of the School SUNITA GYAN NIKETAN SCHOOL
2. School Address VILLAGE & POST OFFICE CHHAWLA, NEW DELHI-110071
3. No. of Shift ONE Timing 08:00 AM TO 01:20 PM
4. No. of Students: Boys =113 Girls =76 Total =189
5. No. of Staffs: Male 0 Female 15 Total =15

DETAILS OF ACCOMMODATIONS PRESENT IN SCHOOL

1. Floor Space in the Classroom Sufficient/insufficient SUFFICIENT
2. The Classrooms are Well Lighted/ ill lighted WELL LIGHTED
3. The Classrooms are Well Ventilated/ ill ventilated WELL VETILATED
4. The Classrooms are kept / Not kept Neat & Clean: NEAT AND CLEAN
5. The Classrooms/Building requires/ do not required Whitewash etc. NOT REQUIRED
6. The Drinking Water is Wholesome/ not wholesome WHOLESOME
7. The Latrine arrangement is Sanitary/ insanitary SANITARY FROM HEALTH POINT OF VIEW.

NO. OF TOILETS SEATS FOR STUDENT

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate V.GOOD FROM HEALTH POINT OF VIEW AND
VALID UP TO ONE YEAR FROM ISSUANCE DATE.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.


Deputy Health Officer

Najafgarh Zone
Deputy Health Officer
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remark: Certificate is valid for one year)